
UNITED STATES POSTAL SERVICE


NORTHERN VIRGINIA VEHICLE MAINTENANCE FACILITY (VMF)
NGDV/ EV CHARGING DEPLOYMENT

2935 PROSPERITY AVENUE, FAIRFAX, VA 22031

USPS PROJECT NUMBER:	K33601
AECOM PROJECT NUMBER:	60711358
DATE: 09/02/2026	BID SET SUBMISSION



VICINITY MAP
NOT TO SCALE



LOCATION MAP
NOT TO SCALE

© Copyright 1997–2008, United States Postal Service

AECOM
1255 Broad Street
Clifton, NJ 07013-3591
(973) 883-8500 tel (973) 883-8501 fax
www.aecom.com

USPS - NORTHERN VIRGINIA VMF
2935 PROSPERITY AVE
FAIRFAX, VIRGINIA, 22031

UNITED STATES POSTAL SERVICE

G0.00 COVER SHEET

Scale: NONE
Project:
USPS File Number: K33601

Date: 09/02/2026

Revisions:

Document Release:

DESIGN CRITERIA

IBC –2021 VIRGINIA INTERNATIONAL BUILDING CODE
NFPA 70 –2020 NATIONAL ELECTRICAL CODE
NFPA 70E –2021 STANDARD FOR ELECTRICAL SAFETY IN THE WORKPLACE
NFPA 101 –LIFE SAFETY CODE
USPS SDC –2023 USPS BUILDING DESIGN STANDARDS
USPS ELECTRIC VEHICLE SITE DESIGN MANUAL 2024–4

GENERAL NOTES

THE FOLLOWING NOTES SHALL APPLY THROUGHOUT CONTRACT DOCUMENTS, UNLESS OTHERWISE NOTED.

1. COMPLY WITH APPLICABLE OSHA REQUIREMENTS, SAFETY CODES AND STANDARDS, BUILDING CODE IN THE JURISDICTION OF THE PROJECTS.
2. THESE DRAWINGS REPRESENT FIELD OBSERVATION, NO HISTORIC AS–BUILT AVAILABLE DURING AECOM SURVEY, AND MAY NOT DEPICT EXACT EXISTING CONDITIONS AND/ OR LOCATIONS, PROFILES, ETC. GENERAL CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFYING ALL EXISTING CONDITIONS AND ABOVE CEILING CONDITIONS PRIOR TO BIDDING THE WORK. IN SUBMITTING A BID ON THIS PROJECT, CONTRACTOR UNDERSTANDS THAT ADDITIONAL PAYMENTS WILL NOT BE MADE FOR DEMOLITION OR RELOCATION OF EXISTING ELEMENTS IN ORDER TO ACCOMPLISH THE WORK. CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS AND NOTIFY THE ARCHITECT AND OWNER'S REPRESENTATIVE IMMEDIATELY OF ANY DISCREPANCIES. PRIOR TO SUBMISSION OF BID, CONTRACTORS SHALL VISIT THE PROJECT SITE AND CAREFULLY EXAMINE EXISTING CONDITIONS ON THE PREMISES AND COMPARE THEM WITH EXISTING CONDITIONS INDICATED ON PLANS. SUBMITTAL OF BID SHALL INDICATE THAT CONTRACTORS HAVE EXAMINED THE SITE, EXISTING CONDITIONS AND PREMISES AND HAS INCLUDED ALL REQUIRED ALLOWANCES IN THE BID. NO ALLOWANCE SHALL BE MADE FOR ANY ERROR RESULTING FROM CONTRACTORS FAILURE TO VISIT THE JOB SITE.
3. CONTRACTOR SHALL VERIFY/CONFIRM ALL RELEVANT DIMENSIONS, ELEVATIONS, GRADES AND CONDITIONS OF THE SITE AND/OR BUILDING PRIOR TO THE COMMENCEMENT OF CONSTRUCTION AND/OR ORDERING OF EQUIPMENT OR MATERIALS.
4. DRAWINGS ARE PRINTED ON 30" BY 42" SIZE. DOCUMENTATION IS PROVIDED FROM MULTIPLE SOURCES – FIELD VISITS, OWNER PROVIDED INFORMATION, ETC.
5. COORDINATION OF ALL WORK UNDER THIS CONTRACT SHALL BE MAINTAINED/SCHEDULED TO ENSURE THE QUALITY AND TIMELY COMPLETION OF THE PROJECT DELIVERY.
6. PERFORM ALL CUTTING, PATCHING, DEMOLITION AND REMOVAL REQUIRED TO COMPLETE THE WORK, WHETHER OR NOT SPECIFICALLY INDICATED.
7. WHERE MANUFACTURERS NAMES AND PRODUCT NUMBERS ARE INDICATED ON THE DRAWINGS, IT SHALL ESTABLISH THE LEVEL OF QUALITY FOR THE PROJECT. OTHER PRODUCTS MAY BE SUBMITTED ACCORDING TO THE PROVISIONS OF THE SPECIFICATIONS.
8. MAINTAIN ALL REQUIRED EXITS FROM THE EXISTING OCCUPIED AREAS THROUGHOUT CONSTRUCTION TO PUBLIC PROPERTY. CONTRACTOR SHALL PROVIDE AND MAINTAIN LIFE SAFETY ELEMENTS THROUGHOUT THE DURATION OF THE PROJECT INCLUDING BUT NOT LIMITED TO: EXISTING EGRESS ROUTES UNLESS SUPERSEDED BY TEMPORARY EGRESS ROUTES, EXIT SIGNAGE, DIRECTIONAL SIGNAGE, LIGHTING LEVELS, EMERGENCY LIGHTING AND CLEAR AISLE PATHWAYS, SITE FIRE LANES AND SITE ACCESS TO EXISTING FACILITIES AND EQUIPMENT IN ACCORDANCE WITH LOCAL AND NATIONAL FIRE DEPARTMENT REGULATIONS.
9. CONTRACTOR SHALL COORDINATE THE PROPOSED WORK WITH EXISTING CONDITIONS AND SHALL COORDINATE PATCHING, GRINDING, AND PREPARATION OF ADJACENT SURFACES TO BE ACCEPTABLE BY BOTH THE OWNER AND WITH THE CONSTRUCTION DOCUMENTS.
10. CONTRACTOR SHALL MAINTAIN A SECURE ENVIRONMENT BETWEEN USPS OPERATIONS AND DEMARCATION WORK AREA (DWA) UNLESS OTHERWISE NOTED.
11. CONTRACTOR IS STRONGLY ENCOURAGED TO ATTEND THE PRE–BID WALK– THROUGH AND FAMILIARIZE HIM/ HERSELF WITH EXISTING CONDITIONS. NO ADDITIONAL FEE REQUEST WILL BE PERMITTED FOR CONTRACTOR ENCOUNTERING CONDITIONS THAT WERE READILY OBSERVABLE AT THE WALK–THROUGH REGARDLESS OF CONTRACTORS ATTENDANCE THERETO. ALSO, CONTRACTOR SHOULD BE AWARE THAT ROOMS WITHIN THE SCOPE OF WORK TYPICALLY CONTAIN PHYSICAL OBSTRUCTIONS THAT MAY REQUIRE PROTECTION AND/OR RELOCATION. CONTRACTOR SHALL COORDINATE RELOCATION WITH POST MASTER. ALL USPS WORK AREAS MUST BE RESTORED TO 'NORMAL OPERATION' CONDITION, TO THE SATISFACTION OF USPS, BEFORE POSTAL WORK BEGINS FOR THE DAY.
12. IT IS NOT EXPECTED THAT ASBESTOS WILL BE ENCOUNTERED IN THE COURSE OF THIS CONTRACT. IF ANY MATERIALS SUSPECTED OF CONTAINING ASBESTOS ARE ENCOUNTERED, DO NOT DISTURB THE MATERIALS. IMMEDIATELY NOTIFY THE CONSTRUCTION MANAGER AND THE OWNER.

STANDARD LIST OF ABBREVIATIONS

A

ACT	ACOUSTICAL CEILING TILE
AFF	ABOVE FINISH FLOOR
ALUM	ALUMINUM
APPROX	APPROXIMATE(LY)
ARCH	ARCHITECTURAL/ARCHITECT

B

BLDG	BUILDING
BLK	BLOCK
BLKG	BLOCKING
BM	BEAM
BO	BOTTOM OF

C

CL or ℄	CENTERLINE
CLG	CEILING
CLO	CLOSET
COL	COLUMN
CONST	CONSTRUCTION
CONT	CONTINUOUS (CONTINUED)
CONTR	CONTRACTOR

D

DIM	DIMENSION
DN	DOWN
DWG(S)	DRAWING(S)

E

EA	EACH
EF	EACH FACE
EJ	EXPANSION JOINT
EL	ELEVATION
ELEC	ELECTRIC (AL)
ENGR	ENGINEER
EP	ELECTRICAL PANEL
EQ	EQUAL
EQUIP	EQUIPMENT
EW	EACH WAY
EXH	EXHAUST
EXIST	EXISTING

F

FAB	FABRIC
FBGL	FIBERGLASS
FD	FLOOR DRAIN
FIN	FINISH
FIN FLR	FINISH FLOOR
FLR	FLOOR
FT	FEET (FOOT)
FTG	FOOTINGS

G

GA	GAGE
GALV	GALVANIZED
GC	GENERAL CONTRACTOR

H

H	HIGH
HORIZ	HORIZONTAL
HP	HIGH POINT
HT	HEIGHT
HVAC	HEATING, VENTILATING AND AIR CONDITIONING

I

ID	INSIDE DIAMETER
IN	INCH
INFO	INFORMATION
INSUL	INSULATION
INT	INTERIOR

J

JST	JOIST
JT	JOINT

L

LAV	LAVATORY
LF	LINEAR FEET
LLH	LONG LEG HORIZONTAL
LLV	LONG LEG VERTICAL
LOC	LOCATION
LP	LOW POINT

M

MAS	MASONRY
MAT	MATERIAL
MAX	MAXIMUM
MECH	MECHANICAL
MFG	MANUFACTURING
MFR	MANUFACTURE (ER) (ED)
MIN	MINIMUM
MISC	MISCELLANEOUS

N

NIC	NOT IN CONTRACT
NO or #	NUMBER
NOM	NOMINAL
NTS	NOT TO SCALE

O

OA	OVERALL
OC	ON CENTER
OD	OUTSIDE DIAMETER
OH	OPPOSITE HAND
OPNG	OPENING
OPP	OPPOSITE

P

PARTN	PARTITION
PL	PLATE
PNL	PANEL
PSF	POUNDS/SQUARE FOOT
PSI	POUNDS/SQUARE INCH
PT	PAINT (ED)

R

REF	REFERENCE
REINF	REINFORCE (ED) (ING)
REV	REVISION or REVISED
RM	ROOM
RO	ROUGH OPENING

S

SCHED	SCHEDULE
SF / SQ FT	SQUARE FEET
SHT	SHEET
SIM	SIMILAR TO
SPEC(S)	SPECIFICATION(S)
SQ	SQUARE
STD	STANDARD
STL	STEEL
STRUCT	STRUCTURE or STRUCTURAL

T

THK	THICK
TO	TOP OF
TOC	TOP OF CONCRETE/CURB
TOM	TOP OF MASONRY
TOS	TOP OF STEEL

U

UL	UNDERWRITERS LABORATORY
UNO	UNLESS NOTED OTHERWISE


V

VERT	VERTICAL

W

w/(o)	WITH/(OUT)
W	WIDTH or WIDE
WD	WOOD
WT	WEIGHT

ARCHITECTURAL GRAPHIC SYMBOLS



DRAWINGS LIST

		05/31/2024 – 30% SUBMISSION	07/01/2024 – BID SUBMISSION	10/10/2025 – BID SUBMISSION	09/02/2026 – BID SUBMISSION
GENERAL SHEETS					
G0.00	COVER SHEET	●	●	●	●
G0.01	DRAWINGS LIST, GENERAL NOTES AND ABBREVIATIONS	●	●	●	●
G0.02	LIFE SAFETY PLAN	●	●	●	●
CIVIL SHEETS					
C1.00	SITE PLAN	●	●	●	●
C2.00	SITE DETAILS	●	●	●	●
ARCHITECTURAL SHEETS					
A1.00	VMF DEMOLITION FLOOR PLAN	●	●	●	●
A2.00	VMF FLOOR PLAN – NEW WORK & LIFT SCHEDULE	●	●	●	●
ELECTRICAL SHEETS					
E0.01	ELECTRICAL GENERAL NOTES	●	●	●	●
E1.00	VMF ELECTRICAL DEMOLITION FLOOR PLAN	●	●	●	●
E2.00	VMF ELECTRICAL FLOOR PLAN	●	●	●	●
E2.01	VMF ELECTRICAL SITE PLAN	●	●	●	●
E3.00	ELECTRICAL ONE LINE DIAGRAM & DETAILS	●	●	●	●

© Copyright 1997–2008, United States Postal Service

AECOM
1255 Broad Street
Clifton, NJ 07013-8591
(973) 883-8500 tel (973) 883-8501 fax
www.aecom.com

USPS - NORTHERN VIRGINIA VMF
2935 PROSPERITY AVE
FAIRFAX, VIRGINIA, 22031

UNITED STATES POSTAL SERVICE

G0.01 DRAWINGS LIST AND GENERAL NOTES AND ABBREVIATIONS

Scale: NONE Date: 09/02/2026 Revisions:
Project:
USPS File Number: K33601 Document Release: